

## BUILDING GUIDELINES

---

Decking must be used for any food truck to prevent damage to the floor/surface. Food Trucks are not permitted on terrazzo surfaces. Decking must be supplied in both absorbent and impervious materials. GWCCA Facility Management can advise or approve of materials.

All food trucks on campus (inside or outside) must comply with all applicable National Fire Protection Association (NFPA) life safety code (see above).

### **Vehicles on Display**

Liquid-fueled or gaseous-fueled vehicles, boats or other motor craft shall not be located indoors except as follows:

1. Batteries are disconnected except where the fire code official requires that the batteries remain connected to maintain safety features.
2. Fuel in fuel tanks does not exceed one-quarter tank or 5 gallons (19 L) (whichever is least). The amount of fuel for Diesel, Propane, Compressed Natural Gas (CNG) or Liquid Natural Gas (LNG) is limited to 5 gallons or less. These vehicles are required to have a shut-off valve on the storage container. For Hydrogen Vehicles, the fuel valve must be in the off position but no requirement on amount of hydrogen fuel.
3. Fuel tanks and fill openings are closed and sealed to prevent tampering.
4. Vehicles, boats or other motor craft equipment are not fueled or defueled within the building.

Separate batteries that are used for auxiliary equipment are allowed to remain connected. Visqueen or another floor protector must be placed under the vehicle.

Any vehicles inside the building must be included on the floor plan and EAP plan and are subject to State Fire Marshal approval.

A vehicle handling charge will be assessed at prevailing rates for each vehicle to be placed on any upper level of the GWCC. The GWCCA Engineering Team will guide vehicles to their final placement location.

Vehicles that are non-compliant with Vehicle on Display are required to use [Fire Watch](#).

### **Fire Watch**

A temporary measure intended to ensure continuous and systematic surveillance of a building or portion thereof by one or more qualified individuals for the purposes of identifying and controlling fire hazards, detecting early signs of unwanted fire, raising an alarm of fire and notifying the fire department.

### **Fire Watch Personnel**

Where, in the opinion of the fire code official, it is essential for public safety in a place of assembly or any other place where people congregate, because of the number of persons, or the nature of the performance, exhibition, display, contest or activity, the owner, agent or lessee shall provide one or more fire watch personnel, as required and approved.